

ALUMINIUM CHLORIDE SOLUTION WT10		ACW10005
Issued January 2001		
Appearance:	Clear or slightly hazy yellow liquid	
<u>Property</u>	<u>Units</u>	<u>Specification Limits</u>
Density	Kilogram per litre @ 20°	>1.25
Aluminium Content	% as Al	>5.3
Alumina Content	% as Al ₂ O ₃	>10.0
<u>Impurities</u>	<u>Units</u>	<u>Specification Limits</u>
Arsenic	mg/kg as As	<5
Cadmium	mg/kg as Cd	<5
Mercury	mg/kg as Hg	<1

Purity Standards

Claral WT10 meets the requirements of BS EN 881:2004 type 3

Methods of Analysis

Water Treatment Solutions Ltd. will be pleased to supply details of analytical methods on request

